




Hillsdale Terminal

16-14 A.W.G. Uninsulated Rings

Phone - 1-800-447-3150



- 110 Copper Alloy .030 thickness
- Electro-Tin Plated terminal
 - .0001"-.0003"
- Terminal I.D. - .093

Part #	Stud Size	Barrel Length	Length	W	Stud Diameter (SD)	F	Voltage
10084	#4	1/4	.57	.246	.122/.125	.195	600V
10085~	#6 Slim	1/4	.57	.246	.139/.142	.195	600V
10086*	#6	1/4	.66	.295	.138/.142	.260	600V
10090*	#8	1/4	.71	.324	.168/.171	.295	600V
10098	#8 Slim	1/4	.65	.295	.168/.171	.260	600V
10100*	#10	1/4	.71	.324	.194/.197	.295	600V
10100M	6-8-10	1/4	.81	.340	NA	.345	600V
10101*	1/4	1/4	.89	.470	.263/.265	.405	600V
10102*	5/16	1/4	.89	.470	.324/.327	.405	600V
10103*	3/8	1/4	.99	.558	.394/.398	.469	600V
10104*	1/2	1/4	1.21	.690	.525/.530	.615	600V
10114*	1/4 slim	1/4	.81	.430	.263/.265	.345	600V
10114E	1/4 Short	3/16	.75	.430	.263/.265	.345	600V

All dimensions are in "inches"

* = UL and CSA listed part

~ = CSA listed part

Required per UL/CSA Requirements:

-75° C Max. Temperature Rating

-Crimp tool HT #20591-NH1

-One crimp required

-Strip Length 9/32" (7.1mm)

-Solid or Stranded wire

Agency and Compliance:

-UL Listed, investigated to UL 486 A-B, File NO. ZMVV.E68376

-CSA 22.2 No. 65-03, Certification NO. 207131

WARNING! Installation of electrical wire and terminals can be hazardous if done improperly. Improper use can result in personal injury or property damage. For safe wiring practices, consult National Electrical Code and/or your local building inspector. A licensed electrical contractor or engineer must be consulted to determine that the correct wire and terminal size is used and that it is properly and safely installed for all applications.

All statements, procedural information, and recommendations related to Hillsdale Terminal's products are based on data believed to be reliable, but the precision or completeness is not definite. Before using this product, you must evaluate it and determine if it is suitable for your intended application. You accept all risks and liability associated with such use. Any statements related to the product which are not in Hillsdale Terminal's current publications shall have no force or effect unless expressly agreed upon, in writing, by a sanctioned member of Hillsdale Terminal.